

# Fort Bend Co. MUD 185

## 2017 Annual Water Quality Report

# Fort Bend Co.

## MUD 185

# 2017 Annual Water Quality Report



### Protecting the Water You Drink

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

### Public Participation Opportunities

The Fort Bend Co. MUD 185 Board of Directors meets regularly each month typically at 12:00 PM on the 3rd Wednesday of the month at 9 Greenway Plaza, Suite 1100, Houston, TX 77046. For more information regarding the date, time and location of the meeting call **832-467-1599** or send your comments to:

Fort Bend Co. MUD 185  
17495 Village Green Dr.  
Houston, Texas 77040

### All Drinking Water May Contain Contaminants

When drinking water meets federal standards there may not be any health-based benefits to purchasing bottled water or point of use devices. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at 1-800-426-4791.

### Special Notice:

Required language for ALL community public water supplies: You may be more vulnerable than the general population to certain microbial contaminants, such as Cryptosporidium, in drinking water. Infants, some elderly or immunocompromised persons such as those undergoing chemotherapy for cancer; those who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care provider. Additional guidelines on appropriate means to lessen the risk of infection by Cryptosporidium are available from the Safe Drinking Water Hotline at 1-800-426-4791.

### Important Information about Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline at 1-800-426-4791 or at <http://www.epa.gov/safewater/lead>.

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

The water sources for this water system are a groundwater well located within the District and a groundwater well located within Fort Bend MUD 37. The TCEQ completed an assessment of your source water and results indicate that our sources have a low susceptibility to contaminants. The sampling requirements for your water system are based on this susceptibility and previous sample data. Any detections of these contaminants may be found in this Consumer Confidence Report. For more information on source water assessments and protection efforts at our system, contact the District Operator at **832-467-1599**, or toll free at **1-866-467-1599**. Further details about sources and source-water assessments are available in the Drinking Water Watch at the following URL: <http://dww2.tceq.texas.gov/DWW/>

The Board of Directors of Fort Bend Co. MUD 185 is pleased to give you this report about your drinking water based upon 2017 test results.

### Our Drinking Water Meets or Exceeds All Federal (EPA) Drinking Water Requirements

Este reporte incluye información importante sobre el agua potable. Para asistencia en español, favor de llamar al Operado del Distrito al teléfono **832-467-1599**.



ENVIRONMENTAL DEVELOPMENT PARTNERS

**Fort Bend Co. MUD 185  
Public Water System ID TX0790478**

**2017 Water Quality Report**

**Regulated Contaminants**

Contaminant	Year	Pink Oak Enclave Range of Levels Detected	King Lakes Range of Levels Detected	MCLG	MCL	Unit	Violation	Likely Source of Contamination
Arsenic	2015	0 / 0	2.40 / 2.40	0	10	ppb	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.
	2017	-	-					
Barium	2015	0.171 / 0.171	0.152 / 0.152	2	2	ppm	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
	2016	-	-					
Fluoride	2015	0.21 / 0.21	0.54 / 0.54	4	4	ppm	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
	2016	-	-					
Combined Radium 226/228	2016	NA	1.5 / 1.5	0	5	pCi/L	No	Erosion of natural deposits.
	-	-	-					
Ethylbenzene	2017	0.5 / 0.5	0 / 0	700	700	ppb	No	Discharge from petroleum refineries.
	-	-	-					
Xylenes	2017	0.0043 / 0.0043	0 / 0	10	10	ppm	No	Discharge from petroleum factories; Discharge from chemical factories.
	-	-	-					

**Secondary Constituents**

Calcium	2015 - 2016	52.1 / 52.1	26.2 / 26.2	NA	NA	ppm	No	Erosion of natural deposits.
Iron	2015 - 2016	0.121 / 0.121	0.132 / 0.132	NA	NA	ppm	No	Erosion of natural deposits.
	2015 - 2016	160 / 160	87.2 / 87.2	NA	NA	ppm	No	Erosion of natural deposits.

**Lead and Copper**

Contaminant	Year	MCLG	MCL	AL	90th Percentile	# Sites over AL	Unit	Violation	Likely Source of Contamination
Copper	2017	1.3	1.3	0.00449	0	ppm	No	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.	
Lead	2017	0	15	0.00	0	pb	No	Corrosion of household plumbing systems; Erosion of natural deposits.	

**Disinfectant**

Disinfectant	Year	MRDLG	MRDL	Annual Average	Range of Levels Detected	Unit	Violation	Source of Contaminant
Free Chlorine	2017	4	4	1.44	1.17 / 2.30	ppm	No	Disinfection used to control microbes.

**Definitions -** The following tables contain scientific terms and measures, some of which may require explanation.

AL/G	Action Level Goal. The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.
AL	Action Level. The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Avg	Regulatory compliance with some MCLs are based on running annual average of monthly samples.
Lvl 1	Level 1 Assessment. A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Lvl 2	Level 2 Assessment. A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
MCL	Maximum Contaminant Level. The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
MCLG	Maximum Contaminant Level Goal. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MRDL	Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MRDLG	Maximum residual disinfectant level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MF/L	million fibers per liter (a measure of asbestos)
NA	not applicable
NTU	nephelometric turbidity units (a measure of turbidity)
PC/L	picocuries per liter (a measure of radioactivity)
ppb	micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water
ppm	milligrams per liter or parts per million - or one ounce in 7,350 gallons of water

**The water we conserve today can serve us tomorrow!**

The single most effective conservation step that can be taken inside the home is to install water efficient showerheads. They provide great showers, yet use 30% to 70% less water. - Use half as much water by installing water efficient aerators on the bathroom and kitchen sinks. - Laundry accounts for about 14% of home water use. Adjust the water level on your machine to match the size of your load. - Repair leaks immediately! A dripping faucet can waste 2 gallons of water per hour.

In February 2017, three regular monthly coliform samples were collected and one sample had a positive result for Total Coliform. The District immediately collected three repeat samples that were found to be absent of Total Coliform. The District also collected a source water sample which confirmed the District's water source meets requirements. Total Coliform can be naturally occurring in the environment. The goal for coliform monitoring is that no samples have a positive result, but a positive result is not a violation. The District provides adequate chlorine disinfection and monitors that disinfection daily to ensure the water is protected from microbial contamination.

**Most Importantly, Your Water Meets All State and Federal Drinking Water Requirements.**